

Intertek does hereby certify that an independent assessment has been conducted on behalf of

## **GREENFAN®**

Certificate Number: ZOZ-90160-2022a Initial

Certification Issued: 23 May 2022

Initial Verification Date: 23 May 2022 Certificate Valid Until: 22 May 2023

Applicant Address: 6125 Bear Claw Ln

Bozeman, MT 59715-9101 USA

**Product Category:** Appliances & Electronics

Product Details: See Appendix

Conformance Criteria: Conforms to UL 2998 (3rd Edition, July 10, 2020) clause 6.2, emittance of ozone not exceeding a concentration of 0.005 ppm.

Issuing Office Name & Address: Intertek Testing Services NA, Inc.

4700 Broadmoor Ave SE, Suite 200

Kentwood, MI 49512 USA

Ph: +1-616-656-7401

Jesse Ondersma Certification Officer 23 May 2022

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Certificate are relevant only to the sample tested/inspected. This Certificate by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Intertek Testing Services NA, Inc. 29 September 2020

1 of 2



**Certificate Appendix** 

## **GREENFAN®**

Certificate Number: ZOZ-90160-2022a

Product Category	Air Cleaners, Bipolar Ionizer
Product Name(s)	GreenFan® Bipolar Ionizer
Model Name(s) Included	1600-01
<b>Product Restrictions</b>	None